

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7150-0785:153

Page 1 of 1

**CATEGORY:** Boxes/Pull Stations

**LISTEE:** Wheelock Inc., 273 Branchport Avenue, Long Beach, NJ 07740  
Contact: Luy Nguyen (732) 222-8707

**DESIGN:** Models MPS-100, MPS-200, and MPS-300 noncoded manual pull stations. Model MPS-100, and MPS-300 has no push bar and Model MPS-200 has push bar. All models have hex lock. Suitable for outdoor use when installed with weather proof back box. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as manual pull stations for use with separately listed and compatible fire alarm control units.

**XLF:** 7150-1408:107



---

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**APRIL 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager